

# Post-ROD Analysis 1997 - 2005

presented by

Les Poch  
Argonne National Laboratory  
Argonne, Illinois

at the

GTMAX MODEL REVIEW AND KNOWLEDGE ASSESSMENT WORKSHOP FOR HYDROPOWER

USGS Flagstaff Science Center  
September 1, 2011

# Determine Economic Impact of Operational Restrictions Imposed by the Record of Decision

- Study period is 1997 – 2005
- An economic not financial analysis
- Simulated Glen Canyon Dam (GCD) operation using Pre-ROD and Post-ROD criteria. Compared economic benefits to measure cost of ROD implementation
- The GCDEIS\* estimated the economic impacts of power resource alternatives
- Annualized economic costs were estimated at \$15.1 to \$44.2 million (nominal \$1991)
- Much has changed since the early 1990's when costs were estimated
  - Higher than projected fuel prices
  - Faster than anticipated demand growth
  - Transformed power markets




\*Glen Canyon Dam Environmental Impact Statement (GCD EIS)



# Glen Canyon Dam Hydropower Plant

- On-line in September 1964
- ~1,320 MW operable capacity
- 8 generating units
- Operated by Reclamation
- Power & energy production is marketed by Western




## Ancillary Services

Spinning reserves  
 Regulation  
 Black start  
 etc...


<b>Operational Constraint</b>	<b>Historic Flows (Pre-1991)</b>	<b>ROD Flows (Post 1997)</b>
<b>Minimum release (cfs)</b>	3,000 summer 1,000 rest of year	8,000 - 7 am - 7 pm 5,000 at night
<b>Maximum release (cfs)</b>	31,500	25,000
<b>Daily fluctuations (cfs/24 hrs)</b>	28,500 summer 30,500 rest of year	5,000; 6,000; or 8,000 depending on release volume
<b>Ramp rate (cfs/hr)</b>	Unrestricted	4,000 up 1,500 down



# Operations Before ROD - Large Release Fluctuations in Response to Market Prices




# Operations After ROD - Economic Value of the Hydropower Resource Has Been Reduced







# The Study Period Contains a Wide Range of Hydropower Conditions



# General Downward Hydropower Production




# Experiments Performed at GCD



- ROD created the Glen Canyon Dam Adaptive Management Program to conduct scientific studies and achieve environmental objectives
- Experiments have significant impact on power generation – water is spilled, shifting time of generation from day to night and on-peak to off-peak hours

## Types of Experiments

- Beach/Habitat Building Flow (BHBF)
- Non-Native Fish Suppression Flow (NNFSF)
- Habitat Maintenance Flow (HMF)
- Low Summer Steady Flow (LSSF)
- Aerial Photography Steady Flow (APSF)





# Overview of the Modeling Process

*SLCA/IP  
Hourly  
Firm Loads*

- Ran 2 GTMax simulations; one with ROD, one without ROD
- Data obtained from publicly available sources such as Energy Information Administration, Federal Energy Regulatory Commission, and Western Power Operations & Maintenance Form 59
- Electricity market price data for various hubs obtained from Intercontinental Exchange and CRSP Management Center – used as surrogate for economic value of energy
- Western constructed data on customer contracts that would have been in effect without the ROD for all facilities within Salt Lake City Integrated Projects (SLCA/IP)





# Comparison of Assumptions used in Both Scenarios

<b>Scenario Element</b>	<b>Without ROD</b>	<b>With ROD</b>
<b>Operating Criteria</b>	Prior to stringent environmental constraints defined in Table 2.2	Post-ROD operating criteria defined in Table 2.2
<b>SLCA/IP Contract Terms</b>	Constructed by Western Staff; based on post-1978 marketing approach	Effective April 1998, post-1989 marketing with replacement resource process modifications
<b>Dispatch Objectives &amp; Goals</b>	<ul style="list-style-type: none"> <li>Maximize economic value of SLCA/IP resources with market purchases of low-priced energy for increased sales during high-priced hours</li> <li>No restriction on daily release levels during weekends</li> </ul>	Same as Without ROD, as long as ROD criteria are satisfied.
<b>Experimental Flows</b>	Do not occur	Specified in ROD and occur as historically recorded
<b>AHP Values</b>	Same as With ROD scenario	Historical Values
<b>Minimum Schedule Requirement</b>	Same as With ROD scenario	Historical Values





# Results - Energy Costs



- Costs follow price spreads.
- Different water releases in 2000 and 2001 due to LSSF
- Large price spikes in 2000 and 2001 because of California energy crisis.
- Some experiments increased flows on-peak; decreased off-peak. Note NNFSF occurred in 2003.
- Cost increase in 2004 despite drop in price spread – outage rate cut in half from 2003. More energy in on-peak hours w/o ROD.
- Cost increase in 2005; water spilled during BHBF.



# Results - Capacity & Energy Costs




- Capacity valued at \$83/kW; from Shortage Criteria EIS
- Capacity costs largest in 2000 to 2002; max capacity difference between with & w/o ROD.
- Highest total cost in 2000 and 2001 during California energy crisis.
- Capacity is largest share of total cost except in 2000 and 2001.
- Compare to costs in GCD EIS – convert from \$1991 to \$2009.
- Costs in 2000 and 2001 are much higher than GCD EIS range.
- Average annual ROD cost from current study is \$50 million; within range as calculated in GCD EIS.
- Total cost over \$435 million





# Electricity Prices During California Energy Crisis Fluctuated Wildly

- Interpolation method used to “smooth out” wild swings and remove effect of California energy crisis
- Simulation rerun for 2000 and 2001 as a sensitivity study



# Sensitivity Study Results



- Energy costs are shown at left; only costs in 2000 and 2001 differ from previous figure
- Cost in 2000 is half that in 1999 because of LSSF; despite no change in price spread.
- Substantial increase in 2001 cost because less water released for with ROD case compared to w/o ROD to compensate for higher release in 2000. Again no change in price spread between 2000 and 2001.
- Average cost of \$38 million is within range calculated in GCD EIS.
- Total study period cost is \$330 million







Source: BOR

